

J.R. HENDERSON LABS, INC.

123 Seaman Ave.
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis
Atomic Absorption
Gas Chromatography

(732) 341-1211
FAX (732) 505-1658
ID # 15083

State Certified
Drinking Water Laboratory
Consulting Service

Zadie's of the Oranges
280 South Harrison St., 2nd Floor
East Orange, NJ 07018

SAMPLE #	SAMPLE LOCATION	SAMPLE DATE/TIME	ANALYTE NAME/CODE	ANALYTICAL METHOD	MRL	RESULTS UG/L	ANALYSIS DATE/TIME	ACTION LEVEL UG/L
22-4585.1	Field Blank	5-13-22/07:25	LEAD/1030	200.9	2.0	<2.00	6-14-22/15:08	15
22-4585.2	Room 5-1 st Draw	5-13-22/07:18	LEAD/1030	200.9	2.0	<2.00	6-14-22/16:11	15
22-4585.3	Room 5-Flushed	5-13-22/07:20	LEAD/1030	200.9	2.0	<2.00	6-14-22/16:19	15
22-4585.4	Room 6-1 st Draw	5-13-22/07:11	LEAD/1030	200.9	2.0	<2.00	6-14-22/16:23	15
22-4585.5	Room 6-Flushed	5-13-22/07:13	LEAD/1030	200.9	2.0	<2.00	6-14-22/16:29	15

All samples were run unfiltered (filtration factor 1) unless otherwise noted here.
UG/L=Micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).
* = less than
MRL=Maximum Reporting Limit

Examined By: *Margaret Ellis*
Lab Manager

Date: 6-15-22

CHAIN OF CUSTODY

J.R. Henderson Labs, Inc.
 123 Seaman Ave
 Beachwood, NJ 08722
 782-841-1211
 Fax: 782-905-1658

Customer Name: Zadie's of the Oranges
Customer Address: 280 South Harrison St, 2nd Floor, East Orange, NJ 07018
Phone #: 908-551-7555 Winifred Smith
Email Address: winifred.smith@zadiesato.com

Type of Sample
 AQ= Aqueous
 S= Soil
 MW= Monitoring Well

TB= Trip Blank
 FB= Field Blank
 WW= Waste Water

Sample ID #	Type	Date	Time	Location	# of Bottles	Bact-Total Coliform	Bact-Fecal Coliform	Nitrates	Secondarys	Inorganics	Lead	Manganese	pH	THMs	HAAs	VOC	Arsenic	COD	TSS	TDS	Alkalinity	Temperature	Radiologicals	Ammonia Nit	Sodium	Chloride	
22-4585.1	AQ	5/13/22	7:25	Field Blank	1						X																
22-4585.2	AQ	5/13/22	7:18	Room 5 1st Draw	1						X																
22-4585.3	AQ	5/13/22	7:20	Room 5 Flushed	1						X																
22-4585.4	AQ	5/13/22	7:11	Room 6 1st Draw	1						X																
22-4585.5	AQ	5/13/22	7:13	Room 6 Flushed	1						X																
<div style="position: absolute; top: 10px; left: 10px; border: 1px solid black; padding: 5px;"> OFFICE USE ONLY </div>																											
Relinquished By: <i>[Signature]</i>																											
Relinquished By: <i>[Signature]</i>																											
Relinquished By:																											
Received By: <i>[Signature]</i>																											
Received By:																											
Received By:																											
Time & Date: 5/23/22																											
Time & Date:																											
Time & Date:																											
Cooler Temp:																											
Preservatives:																											
Comments:																											

J.R. HENDERSON LABS, INC.

123 Seaman Ave.
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis
Atomic Absorption
Gas Chromatography

(732) 341-1211
FAX (732) 505-1658
ID # 15083

State Certified
Drinking Water Laboratory
Consulting Service

Zadie's of the Oranges
280 South Harrison St., 2nd Floor
East Orange, NJ 07018

SAMPLE #	SAMPLE LOCATION	SAMPLE DATE/TIME	ANALYTE NAME/CODE	ANALYTICAL METHOD	MRL	RESULTS UG/L	ANALYSIS DATE/TIME	ACTION LEVEL UG/L
22-2851.1	Field Blank	4-1-22/07:15	LEAD/1030	200.9	2.0	<2.00	4-28-22/21:04	15
22-2851.2	2 nd Water Fountain	4-1-22/07:15	LEAD/1030	200.9	2.0	<2.00	4-28-22/21:10	15
22-2851.3	Room 1	4-1-22/07:15	LEAD/1030	200.9	2.0	3.00	4-28-22/21:15	15
22-2851.4	Room 2	4-1-22/07:15	LEAD/1030	200.9	2.0	2.00	4-28-22/21:40	15
22-2851.5	Room 3	4-1-22/07:15	LEAD/1030	200.9	2.0	<2.00	4-28-22/21:22	15
22-2851.6	Room 4	4-1-22/07:15	LEAD/1030	200.9	2.0	9.00	4-28-22/21:28	15
22-2851.7	Room 5	4-1-22/07:15	LEAD/1030	200.9	2.0	23.0	4-28-22/21:38	15
22-2851.8	Room 6	4-1-22/07:15	LEAD/1030	200.9	2.0	16.0	4-28-22/20:28	15
22-2851.9	Room 7	4-1-22/07:15	LEAD/1030	200.9	2.0	6.00	4-28-22/22:05	15
22-2851.10	1 st Water Fountain	4-1-22/07:15	LEAD/1030	200.9	2.0	<2.00	4-28-22/20:16	15
22-2851.1	Field Blank	4-1-22/07:15	COPPER/1022	3111B	40.0	<40.0	5-2-22/14:30	1300
22-2851.2	2 nd Water Fountain	4-1-22/07:15	COPPER/1022	3111B	40.0	200.0	5-2-22/14:30	1300
22-2851.3	Room 1	4-1-22/07:15	COPPER/1022	3111B	40.0	50.0	5-2-22/14:31	1300
22-2851.4	Room 2	4-1-22/07:15	COPPER/1022	3111B	40.0	<40.0	5-2-22/14:33	1300
22-2851.5	Room 3	4-1-22/07:15	COPPER/1022	3111B	40.0	60.0	5-2-22/14:32	1300
22-2851.6	Room 4	4-1-22/07:15	COPPER/1022	3111B	40.0	110.0	5-2-22/14:33	1300
22-2851.7	Room 5	4-1-22/07:15	COPPER/1022	3111B	40.0	100.0	5-2-22/14:33	1300
22-2851.8	Room 6	4-1-22/07:15	COPPER/1022	3111B	40.0	<40.0	5-2-22/14:30	1300
22-2851.9	Room 7	4-1-22/07:15	COPPER/1022	3111B	40.0	80.0	5-2-22/14:33	1300
22-2851.10	1 st Water Fountain	4-1-22/07:15	COPPER/1022	3111B	40.0	240.0	5-2-22/14:29	1300

All samples were run undiluted (0.0100 liter) unless otherwise noted here.
UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion)
< = less than
MRL=Minimum Reporting Limit

Examined By: *Margaret Ellis*
Lab Manager

Date: 5-4-22

CHAIN OF CUSTODY

J.R. Henderson Labs, Inc.
 128 Seaman Ave
 Beachwood, NJ 08722
 732-841-1211
 Fax: 732-505-1638

Customer Name:
 Customer Address:
 Phone #:
 Email Address

Zach's of the Oranges
 280 South Harrison St, 2nd Floor, East Orange, NJ 07018
 908-531-7565 Winifred Smith
 winfred.smith@zachsoftheoranges.com

Type of Sample
 Aq= Aqueous
 S= Soil
 MW= Monitor Well
 TB= Trip Blank
 FB= Field Blank
 WM= Waste Water

OFFICE USE ONLY

Sample ID #	Type	Date	Time	Location	# of Bottles	Bact-Total Coliform	Bact-Fecal Coliform	Nitrates	Secondary's	Inorganics	Pb & Cu	Iron	Manganese	pH	THM's	HAA5	VOC	Arsenic	COD	TSS	TDS	Alkalinity	Temperature	Radionuclides	Ammonia Nit.	Sodium	Chloride			
22-2851.1	AQ	4/1/22	7:15	Field Blank	1						X																			
22-2857.2	AQ	4/1/22	7:15	2nd Water Fountain	1						X																			
22-2857.3	AQ	4/1/22	7:15	Room 1	1						X																			
22-2857.4	AQ	4/1/22	7:15	Room 2	1						X																			
22-2851.5	AQ	4/1/22	7:15	Room 3	1						X																			
22-2857.6	AQ	4/1/22	7:15	Room 4	1						X																			
22-2851.7	AQ	4/1/22	7:15	Room 5	1						X																			
22-2857.8	AQ	4/1/22	7:15	Room 6	1						X																			
22-2857.9	AQ	4/1/22	7:15	Room 7	1						X																			
22-2857.10	AQ	4/1/22	7:15	1st Water Fountain	1						X																			

Relinquished By: *[Signature]*

Relinquished By: *[Signature]*

Relinquished By: *[Signature]*

Received By: *[Signature]*

Received By: *[Signature]*

Received By: *[Signature]*

Time & Date: 4/1/22

Time & Date: 4/1/22

Time & Date: 4/1/22

Comments: